

Thermal Performance tests on 4 Radiators

11, 21, 22 and 33 models

Carried out for
SANICA ISI SANAYI AS

Report 104472/1

Compiled by Tomas Webster

15 December 2022



This page is intentionally left blank

Thermal Performance tests on 4 Radiators

11, 21, 22 and 33 models

Carried out for: SANICA ISI SANAYI AS
Kavakli Mahallesi
Istanbul Caddesi
No:10, P.K:34520
Beylikduzu/ISTANBUL
Turkey

Contract: Report 104472/1

Issued by: BSRIA Limited
Old Bracknell Lane West
Bracknell
Berkshire
RG12 7AH
UK

Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

Email: bsria@bsria.co.uk
Website: www.bsria.com/uk/

QUALITY ASSURANCE

Issue	Date	Compiled by:	Approved by:	Signature
FINAL	15-Dec-2022	Tomas Webster	Mark Roper	
		Engineering Support	Head of Laboratory	



DISCLAIMER

This Document must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This Document has been prepared by BSRIA Limited, with reasonable skill, care and diligence in accordance with BSRIA's Quality Assurance and within the scope of our Terms and Conditions of Business.

This Document is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the Document at its own risk.

SUMMARY

Thermal performance and pressure tests were carried out on four panel radiators in accordance with the procedures contained in BS EN 442-2:2014, using low pressure hot water in the BSRIA radiator test room, described within Section 3 of this report. The work was requested by Sanica and the thermal testing was carried out during the period 14 to 18 November 2022. Pressure testing was carried out on the 13 December 2022.

A summary of the thermal performance is shown below.

Test reference	Height	Width	Panels	Convectors	Output W at 30ΔT	Output W at 50ΔT	Factor K_m	Exponent n
104472A1TW	600	1000	1	1	468	905	5.7827	1.2916
104472A2TW	600	1000	2	1	658	1269	8.2582	1.2871
104472A5TW	600	1000	2	2	838	1633	9.9202	1.3045
104472A4TW	600	1000	3	3	1185	2286	14.9135	1.2864

Full test results are contained within section 5 and 6 of this report.

CONTENTS

1	INTRODUCTION.....	6
2	ITEMS RECEIVED FOR TEST	7
3	TEST FACILITY	8
4	INSTRUMENTATION	9
5	THERMAL RESULTS.....	10
6	PRESSURE TESTS	15

APPENDICES

APPENDIX A:	Product information	16
APPENDIX B:	Manufacturers product information	21

1 INTRODUCTION

Thermal performance and pressure tests were carried out on four panel radiators in accordance with the procedures contained in BS EN 442-2:2014, using low pressure hot water in the BSRIA radiator test room, described within Section 3 of this report. The work was requested by Sanica and the thermal testing was carried out during the period 14 to 18 November 2022. Pressure testing was carried out on the 13 December 2022.

All samples were received on 1 November 2022. All samples were received in good condition.

This report relates to the samples tested and no others.

Comments and opinions are outside the scope of UKAS accreditation.

2 ITEMS RECEIVED FOR TEST

The test samples consisted of four panel radiators from Sanica. These samples consisted of one each of type 11, 21, 22 and 33 radiators.

The samples were designated by the manufacturer as follows:

Type 600 PK11
Type 600 PKP21
Type 600 PKKP22
Type 600 PKKP33

The samples were four tapping panel radiators. Radiators were plumbed top and bottom same end (T.B.S.E.).

The radiators were installed as standard for BS EN 442, but using the supplied mountings for spacing from the chamber wall.

Further details of the test samples can be found in Appendix A, with manufacturer's drawings included in Appendix B to enable the sample types, sizes, test pressures and finish to be verified.

3 TEST FACILITY

The test facility consists of a test room 4.0m (l) x 4.0m (w) x 3.0m (h), which is constructed to the requirements contained in BS EN 442-2:2014, i.e. five water cooled surfaces and one insulated surface against which the test radiator is installed.

When steady state conditions are achieved the appliance output is determined from measurements of the water flow rate and inlet/outlet water temperature difference.

A standard test consists of three test points. For all appliances a first test is carried out with water supply temperature that produces a mean water temperature of 70°C with the water flow rate such that for radiators the inlet/outlet water temperature difference is 10°C. Two further tests are carried out at the water flow rate established in the first test but with different supply water temperatures.

For products marked¹ the temperature drop was set at 5°C to enable the flow rate to remain within the standard measurement uncertainty for the test chamber.

For all tests the enclosure air temperature is controlled to maintain 20°C at the inner room reference point, which is 0.75m from the floor in the centre of the room.

4 INSTRUMENTATION

TEST RECORD SHEET TP21/7 : TEST EQUIPMENT / INSTRUMENTS

	Instrument No.	Calibration expiry date
Weigh scales	2026, 2027	18/01/23
Resistance thermometer (air) reference & radiant shield	329	14/09/23
Resistance thermometers (water) reference	1512-1515	14/09/23
Digital voltmeter 7½ digit (resistance thermometer measurement)	266	14/09/23
Barometer	881	02/12/22
Electronic timer within PC	526	07/12/22
Vernier caliper (0 – 1.5m)	359	22/03/25
Digital caliper (0 – 150mm)	2057	06/05/23
Weigh scales (water content)	188	18/01/23

Comments: None

Test Engineer

Tomas Webster

5 THERMAL RESULTS

Test reference	Height	Width	Panels	Convectors	Output W at 30ΔT	Output W at 50ΔT	Factor K_m	Exponent n
104472A1TW	600	1000	1	1	468	905	5.7827	1.2916
104472A2TW	600	1000	2	1	658	1269	8.2582	1.2871
104472A5TW	600	1000	2	2	838	1633	9.9202	1.3045
104472A4TW	600	1000	3	3	1185	2286	14.9135	1.2864

Results for the products are for those heights tested, enabling catalogues to be generated based on overall linear length for each height tested.

Catalogue outputs can be derived for other lengths of those heights tested by using a linear length constant of 1 (divide test output by test length for relevant height and multiply by desired length). The same method can be used to determine the relevant constant ' K_m ' for a different length using the test values of ' K_m ' as datum. The exponent ' n ' will remain the same as the tested values for each height.

Test data is valid for the type, material and surface finish tested. The data may also be valid for other surface finishes with the same emissivity.

Individual test results for samples in this contract are shown below.

THERMAL PERFORMANCE TESTS ON 4 RADIATORS

Date of Test: 14/11/2022
 Manufacturer: Sanica
 Model Reference: Type 600 PK11
 Test Reference Number: 104472A1TW
 Type of Heater: Single Panel Single Convector
 Surface Finish: White Powder Coat
 Pipework Connections: T.B.S.E.

HEATER DIMENSIONS

Overall Height: (mm) 603
 Overall Length: (mm) 1004
 Overall Depth: (mm) 66
 Convector Height: (mm) 500
 Convector Depth: (mm) 30
 Height above floor: (mm) 110
 Distance from wall: (mm) 10

Radiated heat factor Sk 0.35
 Barometer exponent np 0.60

MEAN TEST VALUES	TEST 1	TEST 2	TEST 3
Room air temperature 0.75m: (°C)	20.3	20.2	20.3
Flow rate (g/s)	19.7	19.6	19.5
Flow enthalpy (J/g)	313.8	219.4	363.8
Return enthalpy (J/g)	268.9	196.2	306.0
Flow temperature (°C)	75.0	52.4	86.9
Return temperature (°C)	64.3	46.9	73.1
Output (W)	883.1	454.5	1130.2
Mean water temperature (°C)	69.6	49.6	80.0
Temperature difference (°C)	49.3	29.5	59.7
Barometric pressure (mbar)	997.1	997.1	997.3
Corrected output (W)	888.6	457.3	1137.2
Estimated output (W)	888.4	457.4	1137.4

PERFORMANCE EQUATION

$$\text{Output (W)} = K_M (\text{mean water temperature} - \text{room air temperature})^n$$

From test results $K_M = 5.7827$
 $n = 1.2916$

VARIATION OF OUTPUT WITH TEMPERATURE DIFFERENCE

TEMPERATURE DIFFERENCE °C	HEAT OUTPUT W
20	277
30	468
40	678
50	905
60	1145
70	1397

THERMAL PERFORMANCE TESTS ON 4 RADIATORS

Date of Test: 15/11/2022
 Manufacturer: Sanica
 Model Reference: Type 600 PKP21
 Test Reference Number: 104472A2TW
 Type of Heater: Double Panel Single Convector
 Surface Finish: White Powder Coat
 Pipework Connections: T.B.S.E.

HEATER DIMENSIONS

Overall Height: (mm) 603
 Overall Length: (mm) 1003
 Overall Depth: (mm) 71
 Convector Height: (mm) 500
 Convector Depth: (mm) 29
 Height above floor: (mm) 110
 Distance from wall: (mm) 39

Radiated heat factor Sk 0.20
 Barometer exponent np 0.70

MEAN TEST VALUES	TEST 1	TEST 2	TEST 3
Room air temperature 0.75m: (°C)	19.5	19.5	19.5
Flow rate (g/s)	29.2	29.1	29.1
Flow enthalpy (J/g)	311.0	216.0	359.7
Return enthalpy (J/g)	268.4	194.3	305.7
Flow temperature (°C)	74.3	51.6	85.9
Return temperature (°C)	64.1	46.4	73.0
Output (W)	1247.6	631.8	1569.8
Mean water temperature (°C)	69.2	49.0	79.5
Temperature difference (°C)	49.7	29.5	60.0
Barometric pressure (mbar)	983.6	983.6	983.8
Corrected output (W)	1268.3	642.3	1595.8
Estimated output (W)	1259.8	643.5	1603.7

PERFORMANCE EQUATION

$$\text{Output (W)} = K_M (\text{mean water temperature} - \text{room air temperature})^n$$

From test results $K_M = 8.2582$
 $n = 1.2871$

VARIATION OF OUTPUT WITH TEMPERATURE DIFFERENCE

TEMPERATURE DIFFERENCE °C	HEAT OUTPUT W
20	390
30	658
40	952
50	1269
60	1605
70	1957

THERMAL PERFORMANCE TESTS ON 4 RADIATORS

Date of Test: 25/11/2022
 Manufacturer: Sanica
 Model Reference: Type 600 PKK22
 Test Reference Number: 104472A5TW
 Type of Heater: Double Panel Double Convector
 Surface Finish: White Powder Coat
 Pipework Connections: T.B.S.E.

HEATER DIMENSIONS

Overall Height: (mm) 604
 Overall Length: (mm) 1002
 Overall Depth: (mm) 106
 Convector Height: (mm) 502
 Convector Depth: (mm) 30
 Height above floor: (mm) 110
 Distance from wall: (mm) 38

Radiated heat factor Sk 0.20
 Barometer exponent np 0.70

MEAN TEST VALUES	TEST 1	TEST 2	TEST 3
Room air temperature 0.75m: (°C)	20.1	19.9	20.4
Flow rate (g/s)	38.8	38.7	38.6
Flow enthalpy (J/g)	315.9	220.6	364.2
Return enthalpy (J/g)	273.5	198.8	310.5
Flow temperature (°C)	75.5	52.7	87.0
Return temperature (°C)	65.4	47.5	74.2
Output (W)	1644.6	841.8	2071.9
Mean water temperature (°C)	70.4	50.1	80.6
Temperature difference (°C)	50.3	30.2	60.2
Barometric pressure (mbar)	1008.2	1009.5	1010.6
Corrected output (W)	1649.0	843.4	2074.7
Estimated output (W)	1644.5	844.0	2078.9

PERFORMANCE EQUATION

$$\text{Output (W)} = K_M (\text{mean water temperature} - \text{room air temperature}) ^n$$

From test results $K_M = 9.9202$
 $n = 1.3045$

VARIATION OF OUTPUT WITH TEMPERATURE DIFFERENCE

TEMPERATURE DIFFERENCE °C	HEAT OUTPUT W
20	494
30	838
40	1220
50	1633
60	2071
70	2532

THERMAL PERFORMANCE TESTS ON 4 RADIATORS

Date of Test: 17/11/2022
 Manufacturer: Sanica
 Model Reference: Type 600 PKK33
 Test Reference Number: 104472A4TW
 Type of Heater: Triple Panel Triple Convector
 Surface Finish: White Powder Coat
 Pipework Connections: T.B.S.E.

HEATER DIMENSIONS

Overall Height: (mm) 604
 Overall Length: (mm) 1004
 Overall Depth: (mm) 162
 Convector Height: (mm) 499
 Convector Depth: (mm) 30
 Height above floor: (mm) 110
 Distance from wall: (mm) 40

Radiated heat factor Sk 0.10
 Barometer exponent np 0.80

MEAN TEST VALUES	TEST 1	TEST 2	TEST 3
Room air temperature 0.75m: (°C)	20.3	19.8	20.4
Flow rate (g/s)	53.1	53.1	52.6
Flow enthalpy (J/g)	316.5	216.7	359.9
Return enthalpy (J/g)	273.4	195.5	307.2
Flow temperature (°C)	75.6	51.8	86.0
Return temperature (°C)	65.3	46.7	73.4
Output (W)	2290.8	1125.2	2773.2
Mean water temperature (°C)	70.5	49.2	79.7
Temperature difference (°C)	50.2	29.5	59.3
Barometric pressure (mbar)	979.9	980.8	998.7
Corrected output (W)	2346.3	1151.8	2801.9
Estimated output (W)	2297.6	1157.6	2846.9

PERFORMANCE EQUATION

$$\text{Output (W)} = K_M (\text{mean water temperature} - \text{room air temperature})^n$$

From test results $K_M = 14.9135$
 $n = 1.2864$

VARIATION OF OUTPUT WITH TEMPERATURE DIFFERENCE

TEMPERATURE DIFFERENCE °C	HEAT OUTPUT W
20	703
30	1185
40	1716
50	2286
60	2891
70	3525

6 PRESSURE TESTS

TEST RECORD SHEET TP21/4 : BURST TEST

BS EN 442-1 : 2014 clause 5.6 requirements

Sample heating appliances shall be subjected to a burst test at a pressure 1.69 times the maximum working pressure (See commentary below).

- The sample under test may deform but shall not rupture.
- The sample radiators shall not be less than 500mm long.

Commentary

The leak testing pressure is specified by the manufacturer (usually on the product drawing) and is at least 1.3 times the quoted maximum operating pressure. This pressure shall not be less than 520 kPa (75.4 psi). BS EN 442-1 : 2014 clause 5.4 refers. Furthermore, the burst test pressure shall be maintained for a minimum period of 2 minutes.

Test instrumentation

	BSRIA instrument number	Calibration expiry date
Standard pressure gauge	1535	15/04/2023
Stopwatch	298	13/01/2023

Test data

Test item reference number	Date of Test	Burst test pressure [1.3 x leak test pressure] (Bar)	Did test item hold burst pressure for a minimum of 2min without rupture Pass/Fail
104472A1TW	13/12/2022	16.9	Pass
104472A2TW	13/12/2022	16.9	Pass
104472A4TW	13/12/2022	16.9	Pass
104472A5TW	13/12/2022	16.9	Pass

TEST ENGINEER

Tomas Webster

APPENDIX A: PRODUCT INFORMATION

TEST RECORD SHEET TP21/1: TEST ITEMS

Contract number

103714/A

Date of receipt	Test Engineer initials	Full description of test item	Test item reference number
	TW	Single white panel radiator with convector, top grille, side plates, 600x1000	104472A1TW
	TW	Double white panel radiator with single convector, top grille, side plates, 600x1000	104472A2TW
	TW	Double white panel radiator with double convector, top grille, side plates, 600x1000	104472A5TW
	TW	Triple white panel radiator with triple convector, top grille, side plates, 600x1000	103174A4AF

Comments:- Test item reference numbers list all items received in the numerical order they were tested.

Test Engineer (signature)

Tomas Webster

TEST RECORD SHEET TP21/2 : PRODUCT INFORMATION

BSRIA test reference number	104472A1TW
Client	Sanica
Manufacturer	Sanica
Product reference number	Type 600 PK11
Product style	Single Panel with Single Convector
Material of construction	Steel, powder coat white
Date of receipt	01/11/2022
Product or packaging markings	Type, Manufacturer, CE
Test start date	14/11/2022
Weight (dry) (kg)	17.5
Water content (kg)	3.10

DIMENSIONAL MEASUREMENTS

Measurement Parameter	Measured value (mm)	Manufacturer's stated value (mm)	EN 442-2 dimensional tolerance (mm or %)	Pass / Fail
Overall height	603	600	+4/-2	Pass
Overall length	1004	1000	+/-5	Pass
Overall depth	66	68	+4/-3	Pass
Convector height	500			
Convector depth	30			

Number of columns per panel	30
Distance installed from the wall (mm)	10
Distance between centres (mm)	545
Panel thickness (mm)	14.38
Convector overall length (mm)	970
Convector thickness (mm)	0.71
Spot weld horizontal pitch (mm)	32.3
Additional information	T.B.S.E. connections

TEST ENGINEER (Signature)

Tomas Webster

TEST RECORD SHEET TP21/2 : PRODUCT INFORMATION

BSRIA test reference number	104472A2TW
Client	Sanica
Manufacturer	Sanica
Product reference number	Type 600 PKP21
Product style	Double Panel with Single Convector
Material of construction	Steel, powder coat white
Date of receipt	01/11/2022
Product or packaging markings	Type, Manufacturer, CE
Test start date	15/11/2022
Weight (dry) (kg)	28.6
Water content (kg)	6.05

DIMENSIONAL MEASUREMENTS

Measurement Parameter	Measured value (mm)	Manufacturer's stated value (mm)	EN 442-2 dimensional tolerance (mm or %)	Pass / Fail
Overall height	603	600	+4/-2	Pass
Overall length	1003	1000	+/-5	Pass
Overall depth	71	68	+4/-3	Pass
Convector height	500			
Convector depth	29			

Number of columns per panel	30
Distance installed from the wall (mm)	39
Distance between centres (mm)	543
Panel thickness (mm)	13.98
Convector overall length (mm)	975
Convector thickness (mm)	0.55
Spot weld horizontal pitch (mm)	32.5
Additional information	T.B.S.E. connections

TEST ENGINEER (Signature)

Tomas Webster

TEST RECORD SHEET TP21/2 : PRODUCT INFORMATION

BSRIA test reference number	104472A5TW
Client	Sanica
Manufacturer	Sanica
Product reference number	Type 600 PKKP22
Product style	Double Panel with Double Convector
Material of construction	Steel, powder coat white
Date of receipt	01/11/2022
Product or packaging markings	Type, Manufacturer, CE
Test start date	25/11/2022
Weight (dry) (kg)	32.9
Water content (kg)	6.28

DIMENSIONAL MEASUREMENTS

Measurement Parameter	Measured value (mm)	Manufacturer's stated value (mm)	EN 442-2 dimensional tolerance (mm or %)	Pass / Fail
Overall height	604	600	+4/-2	Pass
Overall length	1002	1000	+/-5	Pass
Overall depth	106	103	+4/-3	Pass
Convector height	502			
Convector depth	30			

Number of columns per panel	30
Distance installed from the wall (mm)	38
Distance between centres (mm)	547
Panel thickness (mm)	14.04
Convector overall length (mm)	970
Convector thickness (mm)	0.50
Spot weld horizontal pitch (mm)	32.2
Additional information	T.B.S.E. connections

TEST ENGINEER (Signature)

Tomas Webster

TEST RECORD SHEET TP21/2 : PRODUCT INFORMATION

BSRIA test reference number	104472A4TW
Client	Sanica
Manufacturer	Sanica
Product reference number	Type 600 PKKP33
Product style	Triple Panel with Triple Convector
Material of construction	Steel, powder coat white
Date of receipt	01/11/2022
Product or packaging markings	Type, Manufacturer, CE
Test start date	17/11/2022
Weight (dry) (kg)	49.2
Water content (kg)	9.29

DIMENSIONAL MEASUREMENTS


Measurement Parameter	Measured value (mm)	Manufacturer's stated value (mm)	EN 442-2 dimensional tolerance (mm or %)	Pass / Fail
Overall height	604	600	+4/-2	Pass
Overall length	1004	1000	+/-5	Pass
Overall depth	162	160	+4/-3	Pass
Convector height	499			
Convector depth	30			


Number of columns per panel	30
Distance installed from the wall (mm)	40
Distance between centres (mm)	549
Panel thickness (mm)	14.38
Convector overall length (mm)	975
Convector thickness (mm)	0.54
Spot weld horizontal pitch (mm)	32.5
Additional information	T.B.S.E. connections

TEST ENGINEER (Signature)

Tomas Webster

APPENDIX B: MANUFACTURERS PRODUCT INFORMATION





NO	İSİM	TARİH	İMZA	İŞİMLER	İŞİMLER	REVİZYON NO	REVİZYON
1	Gökhan Dindar	23.10.2020				00	1/1
2	Gökhan Dindar	23.10.2020					
3	Unut Gönen	23.10.2020		501-55226010			
4	117						
TEKİR İŞİMLERİNİN İZLENİMİ				TEKİR İŞİMLERİNİN İZLENİMİ		REVİZYON NO	REVİZYON
TIP 22				600 x 1000		SNC-1106	A3

